

GL-TR-89-0247

AD-A215 953

DEVELOPMENT AND USE OF DATA ANALYSIS PROCEDURES FOR THE CRRES
PAYLOADS AFGL-701-2/DOSIMETER AND AFGL-701-4/FLUXMETER AND
APPLICATION OF THE DATA ANALYSIS RESULTS TO IMPROVE THE STATIC AND
DYNAMIC MODELS OF THE EARTH'S RADIATION BELTS

Bronislaw K. Dichter
Frederick A. Hanser

PANAMETRICS, INC.
221 Crescent Street
Waltham, MA 02254

DTIC
ELECTE
DEC 14 1989
S D CS D

SCIENTIFIC REPORT NO. 1


2 October 1989

Approved for Public Release; Distribution Unlimited

GEOPHYSICS LABORATORY
AIR FORCE SYSTEMS COMMAND
UNITED STATES AIR FORCE
HANSCOM AFB, MASSACHUSETTS 01731-5000

89 12 18 0

"This technical report has been reviewed and is approved for publication"



(Signature)

MARILYN R. OBERHARDT
Contract Manager


(Signature)

E. G. MULLEN
Branch Chief

FOR THE COMMANDER


(Signature)

RITA C. SAGALYN
Division Director

This report has been reviewed by the ESD Public Affairs Office (PA) and is releasable to the National Technical Information Service (NTIS).

Qualified requestors may obtain additional copies from the Defense Technical Information Center. All others should apply to the National Technical Information Service.

If your address has changed, or if you wish to be removed from the mailing list, or if the addressee is no longer employed by your organization, please notify AFGL/DAA, Hanscom AFB, MA 01731. This will assist us in maintaining a current mailing list.

Do not return copies of this report unless contractual obligations or notices on a specific document requires that it be returned.

REPORT DOCUMENTATION PAGE				
1a REPORT SECURITY CLASSIFICATION Unclassified		1b RESTRICTIVE MARKINGS		
2a SECURITY CLASSIFICATION AUTHORITY		3 DISTRIBUTION AVAILABILITY OF REPORT Approved for public release; Distribution unlimited		
2b DECLASSIFICATION/DOWNGRADING SCHEDULE				
4 PERFORMING ORGANIZATION REPORT NUMBER(S)		5 MONITORING ORGANIZATION REPORT NUMBER(S) GL-TR-89-0247		
6a NAME OF PERFORMING ORGANIZATION Panametries, Inc.	6b OFFICE SYMBOL (If applicable)	7a NAME OF MONITORING ORGANIZATION Geophysics Laboratory		
6c ADDRESS (City, State and ZIP Code) 221 Cresecent Street Waltham, MA 02254		7b ADDRESS (City, State and ZIP Code) Hanscom AFB Massachusetts 01731-5000		
8a NAME OF FUNDING SPONSORING ORGANIZATION	8b OFFICE SYMBOL (If applicable)	9 PROCUREMENT INSTRUMENT IDENTIFICATION NUMBER F19628-87-C-0169		
8c ADDRESS (City, State and ZIP Code)		10 SOURCE OF FUNDING NOS		
		PROGRAM ELEMENT NO 62101F	PROJECT NO 7601	TASK NO 20
11 TITLE (Include Security Classification) (See Back)		WORK UNIT NO CF		
12 PERSONAL AUTHOR(S) Bronislaw K. Dichter, Frederick A. Hanser				
13a TYPE OF REPORT Scientific #1	13b TIME COVERED FROM TO	14 DATE OF REPORT (Yr, Mo, Day) 1989 October 2	15 PAGE COUNT 14	
16 SUPPLEMENTARY NOTATION				
17 COSATI CODES			18 SUBJECT TERMS (Continue on reverse if necessary and identify by block number)	
FIELD	GROUP	SUB GR		
			Dosimeter Protons,	
			Fluxmeter Bismuth Germanate (BGO) Scintillator	
			Electrons Nuclear Star Event.	
19 ABSTRACT (Continue on reverse if necessary and identify by block number) Earth's magnetospheric radiation enviroment is a major hazard for spaceborne electronic systems. This report documents work aimed at providing the U. S. Air Force with accurate, time dependent radiation belt and cosmic ray environmental specifications. The data for this effort is obtained from two instruments to be flown aboard the Combined Release and Radiation Satellite (CRRES). These instruments are the Energetic Particle Dosimeter and the High Energy Fluxmeter.				
20 DISTRIBUTION AVAILABILITY OF ABSTRACT UNCLASSIFIED UNLIMITED <input checked="" type="checkbox"/> SAME AS RPT. <input type="checkbox"/> DTIC USERS <input type="checkbox"/>			21 ABSTRACT SECURITY CLASSIFICATION Unclassified	
22a NAME OF RESPONSIBLE INDIVIDUAL Marilyn Oberhardt			22b TELEPHONE NUMBER (Include Area Code) (617) 377-3991	22c OFFICE SYMBOL GL/PHE

11. TITLE

Development & Use of Data Analysis Procedures for the CRRES Payloads AFGL-701-2/Dosimeter & AFGL-701-4/Fluxmeter & Application of the Data Analysis Results to Improve the Static & Dynamic Models of the Earth's Radiation Belts

CONTENTS

	<u>Page</u>
LIST OF ILLUSTRATIONS	iv
LIST OF TABLES	iv
1. INTRODUCTION	1
2. PHASE I EFFORT	2
2.1 AFGL-701-2/Dosimeter	2
2.2 AFGL-701-2/Fluxmmeter	7
3. SUMMARY	7
REFERENCES	10

Accession For	
NTIS CRA&I	<input checked="" type="checkbox"/>
DTIC TAB	<input type="checkbox"/>
Unannounced	<input type="checkbox"/>
Justification	
By _____	
Distribution _____	
Availability Codes	
Dist	Avail and/or Special
A-1	

LIST OF ILLUSTRATIONS

<u>Figure</u>	<u>Title</u>	<u>Page</u>
2.1	Isometric View of the CRRES Dosimeter	3
2.2	Cross Section of the CRRESS Fluxmeter	8

LIST OF TABLES

<u>Table</u>	<u>Title</u>	<u>Page</u>
2.1	Characteristics of CRRES Dosimeter	4
2.2	CRRES Dosimeter Compression Counter Charts	5
2.3	Typical Number of CRRES Orbits Required for an Overflow	6
2.4	CRRES Fluxmeter Channel Geometric Factors and Particle Detection Ranges	9

1. INTRODUCTION

The Earth's magnetospheric radiation environment is an important hazard for spacecraft electronic systems in the altitude range from several hundred km to several Earth radii. The Space Physics Division of the Geophysics Laboratory (GL) is engaged in a program to provide the USAF with accurate and time dependent radiation belt and cosmic ray environmental specifications. Much of the data for this effort will come from the Combined Release and Radiation Effects Satellite (CRRES), which is presently estimated to be launched in mid 1990. Two of the particle detection systems on CRRES have been designed, fabricated and calibrated by Panametrics, Inc.: the AFGL-701-2/Energetic Particle Dosimeter and the AFGL-701/High Energy Electron Fluxmeter (Refs. 1-3).

The general objective of this contract is for Panametrics to provide support to GL in analyzing the data from the Dosimeter and Fluxmeter and aid in GL's efforts to update and improve the radiation belt models. The specific objectives of the contract are:

- (a) Prior to the launch of CRRES - provide support in developing the data analysis procedures for the AFGL-701-2/Dosimeter and the AFGL-701-4/Fluxmeter instruments.
- (b) Following the launch of CRRES - apply these procedures to the CRRES data to provide the Dosimeter and Fluxmeter data in a reduced form in a timely manner.
- (c) Use the obtained CRRES data to update and improve the static radiation belt and cosmic ray models and to provide inputs for dynamic radiation belt and magnetic storm models.

The program is split into two parts, Phase I, covering the period before the CRRES launch and Phase II, covering the post launch period. During Phase I a modest level of effort will be expended to develop the Dosimeter and Fluxmeter data analysis and data display procedures. A higher level of effort will be expended during Phase II to finalize the data handling procedures and use the data to update and improve the radiation belt and cosmic ray models.

2. PHASE I EFFORT

The work carried on during this period, as stipulated in the Technical Proposal, has been at a low level of activity. The primary reasons for this are the distant and uncertain CRRES launch date and the possibility of change of the parameters of the CRRES orbit. The count rates in the Dosimeter and Fluxmeter detectors are quite sensitive to the actual spacecraft orbit, so that at this time it is not feasible to construct the final algorithms for the analysis of CRRES data.

2.1 AFGL-701-2/Dosimeter

The CRRES Dosimeter measures electrons above 1 MeV and protons above 20 MeV in 4 channels (Domes), with both flux and dose being measured. Nuclear star events are also measured for each detector. The Dosimeter, shown in Fig. 2.1, is described in Ref. 1, and is similar to the DMSP/F7 Dosimeter described in Ref. 2. The primary detection characteristics of the CRRES Dosimeter are listed in Table 2.1. The flux and dose channel compression count characteristics are given in Table 2.2.

The dosimeter detectors have a 2π sr field-of-view and separate detected pulses into electron (LOLET = 50 to 1000 keV energy loss) and proton (HILET = 1 to 10 MeV energy loss). The star thresholds (40 or 75 MeV) are only sensitive to high energy proton nuclear interactions ("stars") or to heavy cosmic rays. Ref. 2 provides a detailed description of the basic operation of the Dosimeter, including energy loss curves for the four Al dome/detector sets.

The CRRES dosimeter dose channels have been adjusted to overflow in approximately 2 to 40 orbits so that more detailed dose increment data can be obtained. (The DMSP dosimeter required months to overflow.) The overflow intervals for each of the four electron and proton dose channels are listed in Table 2.3. The electron flux used in the calculations was AE4 (Ref. 4) and the proton flux was AP8 MIN. A comparison of flux and dose increment allows the average particle energy loss to be calculated, and can be used to separate protons and electrons in the LOLET channels. Note that LOLET (Low Linear Energy Transfer) and HILET (High Linear Energy Transfer) are actually better descriptions for the electron and proton channels.




Fig. 2.1 Isometric View of the CRRES Dosimeter.

Table 2.1

Characteristics of the CRRES Dosimeter

<u>Dome No.</u>	<u>Al shield (g/cm²)</u>	<u>Det. area (cm²)</u>	<u>G (cm²-sr)</u>	<u>Star thresh. 100 (MeV)</u>
1	0.55	0.00815	0.0250	40
2	1.55	0.051	0.160	40
3	3.05	0.051	0.160	40
4	5.91	1.000	3.14	75

<u>Dome No.</u>	<u>Proton flux prescale</u>	<u>Dose channel calibration</u>	
		<u>Rads (Si)/(output dose count)</u>	
		<u>Electron (LOLET)</u>	<u>Proton (HILET)</u>
1	1	1.16×10^{-2}	3.44×10^{-3}
2	1	1.85×10^{-3}	2.05×10^{-3}
3	1	1.85×10^{-3}	1.10×10^{-3}
4	8	1.94×10^{-4}	8.78×10^{-4}

<u>Dome No.</u>	<u>Electron channel range (MeV)</u>		<u>Proton channel range (MeV)</u>
	<u>Electrons</u>	<u>Protons</u>	<u>Protons</u>
1	> 1	> 130	20-130
2	> 2.5	> 135	35-135
3	> 5	> 140	51-140
4	> 10	> 155	75-155

Table 2.2

CRRES Dosimeter Compression Counter Characteristics

Flux Counters: Output counts

$$\text{Minimum count} = M \times 2^E$$

Electron Channel: $F \times M = 4 \times 4$ bits/overflow at 524288

Proton Channel: $E \times M = 3 \times 5$ bits/overflow at 4096

Notes: Proton Channel No. 4 has a prescale $K_{pf} = 8$,
so input count = $K_{pf} \times M \times 2^E$

Dose Counters: Output counts used with Dose calibration factors

$$\text{Counters: } = R + E \times M$$

$$= 4 + 4 \times 4 \text{ bits}$$

Modified counter version: output counts are

$$D = 16n + R + 16M \times 2^E, E \leq 7 \text{ (or } E < 8)$$

$$\text{where } 0 \leq n \leq 2^{E-1}, \Delta = 2^E \times 16 \text{ (for } \Delta M = 1)$$

$$D = 16n + R + 16 (M + 8 (E - 7)) \times 128, E > 7 \text{ (or } E \geq 8)$$

$$\text{where } 0 \leq n \leq 127, \Delta = 128 \times 16 \text{ (for } \Delta M = 1)$$

$$D \text{ at overflow} = 16 \times 10,240$$

Table 2.3

Typical Number of CRRES Orbits Required for an Overflow

Channel	Dose	
	Electrons	Protons
1	1.4	23.4
2	2.58	41.5
3	245.0	39.6
4	35.6	35.7

2.2 AFGL-701-2/Fluxmeter

The CRRES Fluxmeter measures primarily electrons in the 1 to 10 MeV range in ten intervals. Secondary data provide some information on high energy proton fluxes. The Fluxmeter, illustrated in Fig. 2.2, is designed to measure electrons in the presence of high energy protons. Two solid state detectors and a BGO (Bismuth Germanate) scintillator form the primary triple-coincidence electron detection scheme. A cylindrical anti-coincidence plastic scintillator around the BGO scintillator is used to reject electrons which scatter out of the side of the BGO crystal, to reject edge-cutting proton for some coincidence configurations, and to reduce interference from side-entry high energy protons. The Fluxmeter can have any coincidence or anti-coincidence requirement set by ground command, so there are eight (8) possible operating configurations. The nominal electron channel geometric factors and particle detection energy ranges are given in Table 2.4. A more detailed discussion of the Fluxmeter design and operation is given in Ref. 3.

The CRRES Fluxmeter is designed to measure 1-10 MeV electrons in ten channels, in the presence of large fluxes of high energy (> 100 MeV) protons. This is particularly necessary for measuring these electrons in the inner radiation belt. It is expected that the normal mode of operation will have the two solid state detector coincidences and the plastic scintillator anti-coincidence all enables. However, in-orbit data will be used to verify that this mode provides the most reliable results. The Fluxmeter has a 7.5° half-angle detection cone, so pitch angle distributions will be measured. The nominal geometric factor is $0.012 \text{ cm}^2\text{-sr}$, so that low flux pitch angle distributions may have to be averaged over several spins. Much of the 1-10 MeV electron flux measurements will be the first reliable measurements of this component of the earth's trapped radiation environment.

3. SUMMARY

We are developing algorithms that utilize the known Dosimeter and Fluxmeter responses and various trapped radiation models to estimate the expected on orbit count rates. The preliminary calculation of Dosimeter count rate is complete. Data analysis to determine the Fluxmeter response to electrons is currently under way.

As soon as a firm launch date for CRRES is determined, the Dosimeter and Fluxmeter instruments will be refurbished in preparation for satellite integration. At that time, the effort devoted to this program will increase to insure that all required data analysis algorithms are completed by launch time.




Figure 2.2 Cross Section of the CRRES Fluxmeter

Table 2.4

CRRES Fluxmeter

Channel Geometric Factors and Particle Detection Ranges

Channel Designation	Energy Loss (MeV)	Geometric Factors (cm ² -sr)		Telescope Energy Ranges (MeV)		Omnidirectional Energy Ranges (MeV)	
		Telescope	Omni	Electrons	Protons	Protons	Protons
<u>Solid State Detectors</u>							
> S ₂ , Front	> 0.80	0.167	6.06	-	4.2-130	116-265	
> S ₁ , Front	> 0.50	0.167	6.06	-	4.1-269	116-588	
W ₁ , Front	0.13-0.50	0.167	6.06	> 0.20	3.97-4.12/269-∞	115.51-115.65/588-∞	
W ₂ , Front	0.13-0.80	0.167	6.06	> 0.20	3.97-4.24/130-∞	115.51-115.76/265-∞	
> S ₂ , Back	> 0.80	0.0120	3.11	-	11.2-130	116-265	
> S ₁ , Back	> 0.50	0.0120	3.11	-	11.1-270	116-588	
W ₁ , Back	0.13-0.50	0.0120	3.11	> 0.52	11.00-11.13/270-∞	115.51-115.65/588-∞	
W ₂ , Back	0.13-0.80	0.0120	3.11	> 0.52	11.00-11.23/130-∞	115.51-115.76/265-∞	
<u>BGO Crystal</u>							
> L ₁₀ ⁵	> 9.40	0.0120	78.6	> 10	19.3-∞	117-∞	
> L ₁₀ ⁶	> 9.40	0.0120	78.6	> 10	19.3-∞/(270-∞)*	117-∞	
L ₉ - L ₁₀	7.41-9.40	0.0120	78.6	8 - 10	18.5-19.3	116.29-116.51	
L ₈ - L ₉	5.42-7.41	0.0120	78.6	6 - 8	17.7-18.5	116.07-116.29	
L ₇ - L ₈	4.43-5.42	0.0120	78.6	5 - 6	17.3-17.7	115.96-116.07	
L ₆ - L ₇	3.44-4.43	0.0120	78.6	4 - 5	16.9-17.3	115.84-115.96	
L ₅ - L ₆	2.95-3.44	0.0120	78.6	3.5-4	16.7-16.9	115.79-115.84	
L ₄ - L ₅	2.45-2.95	0.0120	78.6	3-3.5	16.5-16.7	115.73-115.79	
L ₃ - L ₄	1.96-2.45	0.0120	78.6	2.5-3	16.3-16.5	115.68-115.73	
L ₂ - L ₃	1.46-1.96	0.0120	78.6	2-2.5	16.1-16.3	115.62-115.68	
L ₁ - L ₂	0.96-1.46	0.0120	78.6	1.5-2	15.9-16.1	115.57-115.62	
LL - L ₁	0.44-0.96	0.0120	78.6	1-1.5	15.7-15.9	115.51-115.57	
Any BGO (> LL)	> 0.44	0.0120	78.6	> 1	15.7-∞	116-∞	
<u>Plastic Shield Scintillator</u>							
L _s	> 1.	-	525	-	-	-	98-∞

*For coincidence operation.

REFERENCES

1. P. R. Morel, F. A. Hanser and B. Sellers, "Fabricate, Calibrate and Test a Dosimeter for Integration into the CRRES Satellite," report AFGL-TR-86-0001, (December 1985). Scientific Report No. 3 for Contract No. F19628-82-C-0090 (ADA168566).
2. B. Sellers, R. Kelliher, F. A. Hanser, and P. R. Morel, "Design, Fabrication, Calibration, Testing and Satellite Integration of Space-Radiation Dosimeter," report AFGL-TR-81-0354 (December 1981). Final Report for Contract No. F19628-78-C-0247 (ADA113085).
3. R & D Design Evaluation Report for Design, Fabricate, Calibrate, Test and Deliver Two Satellite Electron Flux Detectors (Panametrics, Inc., November 1982). For Contract No. F19628-79-C-0175. (See also) Final Report, AFGL-TR-0205 (ADA190799).
4. The Trapped Radiation Handbook, J. B. Cladis, G. T. Davidson, and L. L. Newkirk, Compilers and Editors-in-Chief, DNA 2524H (up to - Change 5, 21 January, 1977).